

Office of the Executive Engineer Trans.Line
Maintt.Division-I Janipur Jammu.

NO:-TLMDJ-I/870-72
Dt. 6.8.93

M/S Electric Field Co.
New Secretriare,Road,
Jammu.

Sub:- Proformance Certificate Towards the Equipment
Manufactured and supplied.

Ref:- Your No.302-7/TLMD-I/93 dt. 7-7-93.


Sir,

Kindly refer to your above letter vide which
the proformance certificate of the following equipments
supplied^{to} you has be~~re~~ requested from this office.

1. LT Switchgear Panel 3 phase 4 wire 50 cycles
with 2 No. incoming of 400 amps rating and number
of outgoings with various rating complete with
instruments installed at Janipura Receiving
Station, during June 1991.
2. Battery charging equipment suitable for 110 Volt
200 AH capacity battery installed at Janipura
Receiving station during June 1992.
3. Automatic voltage stablizer 3 phase 4 wire of
100 KVA capacity 415 volt installed at Janipura
Receiving station during June 1993.
4. Automatic voltage stablizer 3 phase 4 wire
415 volt capacity 50 KVA installed at Akhnoor
Receiving station during 1993.
5. Battery charging equipment suitable for 110 Volt
200 AH capacity battery installed at Akhnoor
receiving station during Feb.1993.

It is intimate that the proformance ~~repair~~^{report} of the
above equipments is quite satisfactory and are functioning
properly.

Yours faithfully,


Executive Engineer,
T.L.M.D. I Janipur, Jammu.

/Veena/
CC:-

- 1-2) Asstt.Ex.Engineer, T.L.M. Sub-Division No.I/III
Janipur/Akhnoor for information and necessary
action.This is as per the report furnished by you
vide your No.TLMSD-I/311 dt. 26-7-93/AKH/SD-III/511
dt. 14-7-1993.